



SISTEMUL HIDROTEHNIC VOILA - LABORATOR CALITATEA APEI VOILA

Sos.Paltinului nr.19, Campina Tel. 0769074796

Laborator inreg. la Ministerul Sanatatii pentru monitorizarea calitatii apei potabile conf. Legii 458/2002

RAPORT DE INCERCARE NR: 409 / DATA: 17.03.2022

BENEFICIAR.....

PROBA DE ANALIZAT - apa potabila clorinata - Nod Hidrotehnic Movila Vulpilor

Prelevare: - punct de prelevare - **Intrare fir1 potabil Voila**

- metoda de prelevare -SR ISO 5667-5/2017

- prelevatorul -Laborator Calitatea Apei Voila

Data prelevarii probei: 17.03.2022-ora 20

Data receptiei probei: 17.03.2022 - ora 21

Data executarii analizei: 17.03.2022-ora 21-22

NOTE:

1.Acest raport de incercare se refera numai la proba de apa specificata.

2.Se interzice reproducerea totala sau partiala a acestui raport de incercare fara aprobarea emitentului

NR. CRT	DENUMIREA ANALIZEI	METODA DE ANALIZA	LIMITE ADM. CF. LEGII 458/2002 republicata	REZULTAT
1	Turbiditate (NTU)	SR EN ISO 7027-1/2016	5	0,3
2	Gust TFN	SR EN 1622/ 2007	nici o modificare anormala	nicio modificare anormala
3	Miros TON	SR EN 1622/ 2007	nici o modificare anormala	nicio modificare anormala
4	Conductivitate (microS/cm)	SR EN 27888/1997	2500	347
5	Clor rezidual liber/total (mg/l)	SR ISO 7393-2/2018	0,1–0,5 in retea	0,46/0,52
6	pH (unitati ph)	SR ISO 10523/2012	6,5-9,5	7,90
7	Duritate (grade germane)	SR ISO 6059/2008	min 5	9,61
8	Cloruri (mg/l)	SR ISO 9297/2001	250	7,87
9	Indice permanganat (mg O ₂ /l)	SR EN ISO 8467/2001	5	<0,5 (<LOQ)
10	Amoniu (mg/l)	SR ISO 7150/2001	0,5	<0,08 (<LOQ)





NR. CRT	DENUMIREA ANALIZEI	METODA DE ANALIZA	LIMITE ADM. CF. LEGII 458/2002 republicata	REZULTAT
11	Nitriti (mg/l)	SR EN 26777/2002 C 91/2006	0,5	<0,017 (<LOQ)

LOQ= limita de cuantificare

Inginer chimist

Nume: Anghel

Prenume: Cristina

Semnatura

Biolog

Nume: Sinca

Prenume: Anda

Semnatura

Sef de laborator

Nume: Gologan

Prenume: Daniela

Semnatura

RAPORT DE INCERCARE NR: 409 / DATA: 17.03.2022

