



SISTEMUL HIDROTEHNIC VALENII DE MUNTE - LABORATOR CALITATEA APEI VALENII DE MUNTE

Str. Bratocea, nr. 21, Valenii de Munte, Jud. Prahova, Tel.: 0769074807/0786017942
Laborator inregistrat la Ministerul Sanatatii Publice pentru monitorizarea calitatii apei potabile
conform Legii 458/2002, reactualizata

BULETIN DE ANALIZA NR: 207 / DATA: 05.07.2021

BENEFICIAR-

PROBA DE ANALIZAT- apa potabila

Prelevare:

- punct de prelevare - IESIRE STA VALENII DE MUNTE
- metoda de prelevare - SR ISO 5667-5/2017, SR EN ISO 19458/2007
- prelevatorul - LABORATOR C.A. VALENII DE MUNTE

Data prelevării probei: 05.07.2021

Data executării analizei: 05.07.2021 ÷ 08.07.2021

NOTE:

1. Acest buletin de analiza se refera numai la proba de apa specificata.
2. Se interzice reproducerea totala sau partiala a acestui buletin de analiza fara aprobarea emitentului.
3. Determinarea performantelor metodelor de analiza s-a efectuat conform cu cerintele legii 458/2002, reactualizata.

REZULTATE:

Nr. crt.	Denumirea analizei		Metoda de analiza		Limite adm. cf. legii 458/2002, reactualizata	Performanta metodei de analiza			Rezultat
			Standard	Procedura de laborator		Domeniu de aplicare	Incertitudine extinsa relativa (k=2)	Limita de cuantificare	
1.	Turbiditate (N.T.U)		SR EN ISO 7027-1/2016	PAL 02	5	LQ÷10	± 14 %	0.14 NTU	0.3
2.	Culoare (m ⁻¹)		SR ISO 7887/2012	PAL 04	nici o modificare anormala	LQ÷40	± 15 %	0.13 m ⁻¹	nici o modificare anormala
3.	Gust TFN		SR EN 1622/2007	PAL 03	nici o modificare anormala	-	-	-	nici o modificare anormala
4.	Miros TON		SR EN 1622/2007	PAL 03	nici o modificare anormala	-	-	-	nici o modificare anormala
5.	Conductivitate (µS/cm)		SR EN 27888/1997	PAL 05	2500	LQ÷3000	± 14 %	16 µS/cm	335
6.	Clor rezidual (mg/l)	liber	SR EN ISO 7393-2/2018	PAL 39	0.10÷0.50 in retea ≥ 0.50 la iesire statie de tratare	LQ÷2	± 7.5 %	0.09 mg/l	0.68
		total							0.73
7.	pH (unitati pH)		SR ISO 10523/2012	PAL 06	6.5÷9.5	LQ÷14	0.1 unit. pH	0.8 unit. pH	7.45
8.	Duritate (grade germane)		SR ISO 6059/2008	PAL 08	minim 5	LQ÷30	± 13 %	2.35 gr. germ.	8.86
9.	Cloruri (mg/l)		SR ISO 9297/2001	PAL 10	250	LQ÷300	± 11 %	4.11 mg/l	19.14
10.	Aluminiu (mg/l)		SR ISO 10566/2001	PAL 15	0.2	LQ÷0.3	± 21 %	0.028 mg/l	0.095

Cod: F-LAB-10

Versiunea 4.0.



Str. Gh. Gr. Cantacuzino nr. 304. Ploieşti - Prahova Web: www.eszph.ro

Tel.: 0244-517.837 / 513.157/512.600 Fax: 0244-595.016 / 515.035

C.I.F. RO 18856244 / Nr. Inreg. R.C.: J29 / 1547 / 2006 / Cod Poştal: 100466



Nr. crt.	Denumirea analizei	Metoda de analiza		Limite adm. cf. legii 458/2002, reactualizata	Performanta metodei de analiza			Rezultat
		Standard	Procedura de laborator		Domeniu de aplicare	Incertitudine extinsa relativa (k=2)	Limita de cuantificare	
11.	Indice de permanganat (mg O ₂ /l)	SR EN ISO 8467/2001	PAL 12	5	LQ÷10	± 9 %	0.47 mg/l	0.96
12.	Amoniu (mg/l)	SR ISO 7150-1/2001	PAL 21	0.5	LQ÷0.24	± 24 %	0.038 mg/l	SLQ
13.	Nitriti (mg/l)	SR EN 26777/2002	PAL 22	0.5	LQ÷0.2	± 12 %	0.019 mg/l	SLQ
14.	Nitrati (mg /l)	SR ISO 7890-3/2000	PAL 25	50	LQ÷50	± 14 %	2.0 mg/l	2.64
15.	N formula (mg/l)	Legea 458/2002	-	$\frac{[\text{nitrat}]}{50} + \frac{[\text{nitrit}]}{3} \leq 1$	-	-	-	0.052
16.	Sulfati (mg/l)	STAS 3069/1987	PAL 42	250	LQ÷300	± 12.2 %	5.43 mg/l	23.21
17.	Fier (mg/l)	SR ISO 6332/1996-C91/2006	PAL 19	0.2	LQ÷1.9	± 15 %	0.028 mg/l	0.058
18.	Sodiu (mg/l)	Metoda electrochimica	PAL 31	200 mg/l	LQ÷1000	± 14.6 %	5.35 mg/l	10.16
19.	Numar de colonii la 22°C (UFC/ml)	SR EN ISO 6222/2004	PAL 26	nici o modificare anormala	-	-	0.2	0
20.	Numar de colonii la 37°C (UFC/ml)	SR EN ISO 6222/2004	PAL 26	nici o modificare anormala	-	-	0.2	0
21.	Bacterii coliforme totale (numar/100ml)	SR EN ISO 9308-1/2015 /A1:2017	PAL 27	0	-	-	4	0
22.	Escherichia Coli (numar/100ml)	SR EN ISO 9308-1/2015 /A1:2017	PAL 27	0	-	-	4	0
23.	Enterococi (numar/100ml)	SR EN ISO 7899-2/2002	PAL 28	0	-	-	4	0
24.	Clostridium perfringens (numar/100ml)	SR EN ISO 14189/2017	PAL 29	0	-	-	4	0

*LQ = limita de cuantificare;
SLQ = sub limita de cuantificare.

Intocmit,
Resp. analiza:

JERCAN
LARISA

Biolog:

ANGHEL
IRINA

Verificat,
Coordonator lab.:

JERCAN
LARISA

Aprobat,
Sef laborator:

MATACHE
GIANINA

Semnatura:

BULETIN DE ANALIZA NR: 207 / DATA: 05.07.2021

E.S.Z. PRAHOVA S.A.
S H VĂLENII DE MUNTE
LABORATOR VĂLENII DE MUNTE

Cod: F-LAB-10

Versiunea 4.0.

